

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



Test Report

No. 11-003575-PR01

(PB-A01-02-en-01)

Client
KURTOGLU ALUMINYUM
BAKIR KURSUN SAN. A.S.
Haciseremet Mevkii TEM Corlu Cikisi Velimese
59860 Tekirdag
Turkey

Product
Tilt and turn window with fixed sublight

Designation
System designation: 40 C

Performance-relevant product details
Material: Aluminium profiles

Overall dimensions (WxH)
792 mm x 2,000 mm

Special features

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented, in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 20 pages.

Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class E1200

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



Class C3 / B3

ift Rosenheim

20.01.2012

Jörn Peter Lass, Dipl.-Ing. (FH)
Head of Testing Department
Building Components

Robert Kolacny, Dipl.-Ing. (FH)
Operating Product Officer
Building Components



ift Rosenheim GmbH
Geschäftsführer
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Gietl-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Str. 83026 Rosenheim
A3 Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 600 00

Notified Body Nr.: 0757
Anerkannte PLZ-Stelle BAY 18

DIN EN ISO 9001
DIN EN ISO 14001
TSA-DA 99-99-80
TSA-DA 99-99-80