

Classification Report

Number	22-003418-PR01 (NW-C01-02-en-01)
Owner	KURTOGLU ALUMINYUM BAKIR KURSUN SAN. A.S. Haciseremet Mevkii TEM Corlu Cikisi Velimese 59860 Tekirdag Turkey
Product	External pedestrian doorset
Designation	System: 84FD Shipping name: 84FD
Details	Material Aluminium system with thermal break; Overall dimensions (W x H) 1100 x 2100 ; Closing condition closed and locked; Threshold: Designation 84FD-401-18; System 84FD; Material Aluminium system with thermal break; Lock: Designation GU-SECURY SH2
Special features	Test sequence. Material compatibility must be taken into account. Material durability must be taken into account.

Result **)

Air permeability according to EN 12207:2016-12

**Class: 4**

Resistance to wind load according to EN 12210:2016-03

**Class: C3**

Watertightness according to EN 12208:1999-11

**Class: 9A**

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim

02.11.2022



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 22-003418-PR01 PB-
C01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 01D-BD6A0