

Classification Report

Number	21-001644-PR02 (NW-A01-02-en-02)
Owner	KURTOGLU ALUMINYUM BAKIR KURSUN SAN. A.S. Haciseremet Mevkii TEM Corlu Cikisi Velimese 59860 Tekirdag Turkey
Product	Tilt and turn window with fixed sublight
Designation	System: 84TH Shipping name: 84TH
Details	Manufacturer: KURTOGLU ALUMINYUM, BAKIR KURSUN SAN. A.S. - Tekirdag; Material: Aluminium system with thermal break; Type of opening: Tilt and turn; Opening direction: DIN right, inward opening; Overall dimensions (W x H): 792 mm x 2000 mm
Special features	Material compatibility must be taken into account. Material durability must be taken into account.
Result	

Air permeability according to EN 12207:2016-12

**Class: 4**

Resistance to wind load according to EN 12210:2016-03


**Class: C4/B4**

Watertightness according to EN 12208:1999-11

**Class: E1200**

ift Rosenheim

01.04.2021



Robert Kolacny, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 21-001644-PR02 PB-
A01-02-en-02

Replaces ift-Nachweis: 21-
001644-PR02 NW-A01-02-en-01
dated 31.03.2021.

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 576-9EFS6